

**Sanitary Sewer Overflow Report for 2010**

Incident Number	Incident Date	Site Address	Site Name	Responsible Party	Description of Incident	Total Overflow Amount (gallons)	Amount Reaching State Waters (gallons)
SSORS#2010-T-102418	2/5/2010	315 Center Avenue	Center Avenue Pump Station	HRSD	High flows from rain are causing pump station to overflow intermittently at an estimated 5 gpm. Rain gauge at City of Hampton Freeman PS recorded 2" of rainfall in 24 hours.	4730	4730
SSORS#2010-T-102425	2/6/2010	Lucas Creek Road	Lucas Creek Pump Station	HRSD	Pump station overflowed intermittently at estimated rate of 5 gpm due to high flows from rain.	150	150