



## INVITATION FOR BIDS

2009-2756-0805  
December 16, 2008

OFFICE OF THE PURCHASING DIRECTOR  
2400 Washington Avenue  
Newport News, VA 23607

Phone: (757) 926-8721/ Fax: (757) 926-8038  
[www.nngov.com/purchasing](http://www.nngov.com/purchasing)

---

### Doris Miller Recreation Center Boiler Replacement

### ADDENDUM 3

**Bid Due:** December 16, 2008 at 4:00 p.m.

**Contracting Officer:** \_\_\_\_\_  
*Jerry Stokes, Buyer, [jstokes@nngov.com](mailto:jstokes@nngov.com) 757-926-8033*

- The attached response to the question has been added for clarification.
- **Addendum 3 will not be required to be submitted with bid.**
- All other terms and conditions remain unchanged.

Company Name: \_\_\_\_\_

Address: \_\_\_\_\_

City/State/Zip: \_\_\_\_\_

Telephone: \_\_\_\_\_ FAX No.: \_\_\_\_\_

E-mail: \_\_\_\_\_

Federal Tax ID (or Social Security #): \_\_\_\_\_

Print Name: \_\_\_\_\_ Title: \_\_\_\_\_

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

*(This Form Must Be Signed. Signature must be original, not photocopied)*

## **Response to Question**

### **Questions:**

In regards to the #2 Addendum, you request a quote for 'temporary' heat. Do you wish to install a temporary boiler to provide heat while the boiler is being replaced, which MAY take as long to connect and disconnect as it takes for the boiler replacement, OR do you wish to have temporary space heaters, and if so, do you know how many spaces will require heating?

### **Response:**

The temporary heat required will only be that needed to keep building pipes from freezing during the boiler down time. According to the Department of Parks, Recreation and Tourism, there will not be any scheduled activities in the building during the time of boiler replacement.