
INVITATION FOR BIDS

January 7, 2009

IFB #2009-3948-2205

City of Newport News
OFFICE OF THE PURCHASING DIRECTOR
2400 Washington Avenue
Newport News, VA 23607



Phone: (757) 926-8721/ Fax: (757) 926-8038

Drainage Improvements to Huntington Heights, Phase I

ADDENDUM 4

BID DUE: January 15, 2009 at 2:00 P.M.

Contract Officer:

Bill Lindsey, CPPO, C.P.M., Purchasing Administrator, blindsey@nngov.com

Be Advised of the following changes and information related to the subject solicitation:

- Page B-2, Bid Form: Change the Approximate Quantity for Item 9 from 120 CY to 200 CY.
- Page B-2, Bid Form: Add Items 35 and 36 as listed below:

ITEM	DESCRIPTION	APPROX. QUANTITY	UNIT	UNIT BID	UNIT TOTAL
35	IM-1A, Asphalt Intermediate Course (2")	5	CY		
36	Milling	1,390	SY		

- Page B-6: Substitute Item No. 9 with the following paragraph:

9. SM-9.5A ASPHALT SURFACE COURSE (2")

Payment shall be at the unit price bid per cubic yard to include all costs for labor, materials, hardware, equipment, services, and incidentals required to provide and place asphalt surface course **to cover the top two (2) inches of the pipe trenches and the entire milled area along 65th Street** between Warwick Blvd and Huntington Avenue, as indicated on the construction drawings, or as directed by the Engineer. The unit price shall include, but not be limited to, providing and placing tack coat; and any striping and/or placement of pavement markings. The pavement section shall be in accordance with the VDOT Road and Bridge Specifications. Quantity shall be based on field measurements made by the Engineer.

- Page B-10: Add the following paragraphs 35 and 36 listed below.

35. IM-1A ASPHALT INTERMEDIATE COURSE (2")

Payment shall be at the unit price bid per cubic yard to include all costs for labor, materials, hardware, equipment, services, and incidentals required to provide and place asphalt intermediate course along the pipe trench that crossing Huntington Avenue and between Base and surface Layers, or as directed by the Engineer. The pavement section shall be in accordance with the VDOT Road and Bridge Specifications. Quantity shall be based on field

measurements made by the Engineer.

36. MILLING

Payment shall be at the unit price bid per square yard to include all costs for labor, materials, hardware, equipment, services, and incidentals required to mill approximately two (2) inches of the existing pavement section along 65th Street from Warwick Blvd to Huntington Avenue. The unit price shall include, but not be limited to, all necessary repair and/or adjustment to the existing stormwater/sanitary sewer structures, curb & gutters, and other existing utilities. Quantity shall be based on field measurements made by the Engineer.

- Page C-3, Contract: Change the Approximate Quantity for Item 9 from 120 CY to 200 CY.
- Page C-3, Contract: Add Items 35 and 36 as listed below:

ITEM	DESCRIPTION	APPROX. QUANTITY	UNIT	UNIT BID	UNIT TOTAL
35	IM-1A, Asphalt Intermediate Course (2")	5	CY		
36	Milling	1,390	SY		

- Page C-11: Add the following paragraphs 35 and 36 listed below.

35. IM-1A ASPHALT INTERMEDIATE COURSE (2")

Payment shall be at the unit price bid per cubic yard to include all costs for labor, materials, hardware, equipment, services, and incidentals required to provide and place asphalt intermediate course along the pipe trench that crossing Huntington Avenue and between Base and surface Layers, or as directed by the Engineer. The pavement section shall be in accordance with the VDOT Road and Bridge Specifications. Quantity shall be based on field measurements made by the Engineer.

36. MILLING

Payment shall be at the unit price bid per square yard to include all costs for labor, materials, hardware, equipment, services, and incidentals required to mill approximately two (2) inches of the existing pavement section along 65th Street from Warwick Blvd to Huntington Avenue. The unit price shall include, but not be limited to, all necessary repair and/or adjustment to the existing stormwater/sanitary sewer structures, curb & gutters, and other existing utilities. Quantity shall be based on field measurements made by the Engineer.

Company Name: _____

Address: _____

City/State/Zip: _____

Telephone: _____ Fax No.: _____ E-Mail: _____

Fed. Tax ID (or Social Security #): _____

Print Name: _____ Title: _____

Signature: _____ Date: _____

This form must be signed. All signatures must be original and not photocopies