



NOTES:

1. SEE STANDARD DWG. NO. W-06B FOR ADDITIONAL REQUIREMENTS FOR FIRE HYDRANT SETTING.
2. SIZE OF RCP TO BE DETERMINED BY DEVELOPER'S ENGINEER FOR NEW DEVELOPMENTS.
3. TYPE II-B HYDRANT SETTING TO BE USED WHEN CALLED FOR ON PLANS. USE WHEN DITCH DEPTH (EDGE OF PAVEMENT TO BOTTOM OF DITCH) IS 18" OR MORE, OR HYDRANT VALVE FALLS WITHIN DITCH SLOPE.

CITY OF NEWPORT NEWS
DEPARTMENT OF PUBLIC UTILITIES
NEWPORT NEWS, VIRGINIA

**TYPE II-B FIRE
HYDRANT SETTING
WITH CULVERT**

REVISED BY:	B.W.S.	B.W.S.		DWG. NO.	W-06D	SCALE NONE	DATE
REVISED DATE:	1/98	4/18/00		DWG. FILE NO.		DWN. BY B.S.	10/13/95
				PRINT FILE NO.	N-1809	CKD. BY F.B.	