



INVITATION FOR BIDS

IFB #2009-6796-0205

July 31, 2009

City of Newport News, Dept. of Purchasing
2400 Washington Avenue, 4th Floor, City Hall
Newport News, VA 23607

Phone: (757) 926-8721/ Fax: (757) 926-8038

www.nngov.com/purchasing

Electrical Repairs for Seafood Industrial Park Pier

Addendum #3

- ✍ **Questions/Answers are provided on the following page.**
- ✍ **No additional questions may be submitted (Deadline was 5:00 PM, Monday, August 3rd.)**
- ✍ **The Bid Submittal Deadline remains scheduled as noted below:**

BID DUE: 2:00 PM, August 11, 2009

Contract Officer: _____
Greg Smith, CPPB, C.P.M, Senior Buyer, gsmith@nngov.com

*****AN ORIGINAL AND ONE (1) COPY OF YOUR SUBMITTAL IS REQUESTED*****

Return this Addendum and the original solicitation document with your Bid Submittal.

This public body does not discriminate against faith based organizations

Company Name: _____

Address: _____

City/State/Zip: _____

Telephone: _____ Fax No.: _____ E-Mail: _____

Print Name: _____ Title: _____

Signature: _____ Date: _____

This form must be signed. All signatures must be original and not photocopies.

The following responses to the listed questions shall be included in the contract requirements.

1. (Addendum #1 Point 11) Are all (10) SBPF pedestals being replaced completely or only (5) ? SBFP #1 thru #5 on the furthest part of the pier, more specifically ?

City Response: Only 1 through 5 on the furthest part of the pier.

2. (Addendum #1 Point 8) Is all the conduit and wiring being replaced from Panel SPA to each of the pedestals mentioned above (#1-#5) and then on to the (1) pole light ?

City Response: Yes.

3. (Addendum #2 Question #5) Is the only work to be done on the first section of the pier, from NDP (shore) to the Sub Panel, going to be the (20) clamps included in the base bid as well as additional at the agreed unit cost ?

City Response: Yes, to include rehangng as necessary.

4. All existing conduit and wiring is to remain on this section of the pier ?

City Response: Yes

End of Questions / Answers.

BID FORM

(As Revised, Addendum #1)

Company Name: _____

The above named company offers to provide electrical repair services as specified herein for a Lump Sum amount of :

Figures: \$ _____

Written numbers: _____

The Lump Sum above shall include twenty new stainless steel hangers. However payment shall be based on the actual number of new hangers used, with a deduct or add based on the unit price quoted for the hangers below:

Add/Deduct per each new stainless steel hanger above or below the twenty units included in the Lump Sum amount: \$ _____

The bidder shall complete the following notations as appropriate:

"Licensed Class A Virginia Contractor No. _____."

"Licensed Class B Virginia Contractor No. _____."

"Licensed Class C Virginia Contractor No. _____."

References are required, see original solicitation document.