



Informal Request for Quotations

IRFQ #2010-5943-2005

May 6, 2010

City of Newport News Office of the Purchasing Director

2400 Washington Avenue

Newport News, VA 23607

Phone: (757) 926-8721 Fax: (757) 926-8493

www.nngov.com/purchasing

ADDENDUM 1

Demolition of Old Ivy Farms Pool, 691 Dresden Drive for Codes Compliance, Pkg. 3 - 2010

It is agreed and understood that this addendum shall be made part of the original Informal Request for Quotations document. It provides responses to questions asked, and clarification.

Quotation Due: May 11, 2010 @ Close of Business

Contract Officer: _____
Shari D. Colvin, CPPB, VCO, Deputy Director, scolvin@mngov.com

Company Name: _____

Address: _____

City/State/Zip: _____

Telephone: _____ Fax No.: _____

Email: _____

Print Name: _____ Title: _____

Signature: _____ Date: _____

(This Form Must Be Signed. Signature must be original, not photocopied)

RESPONSES TO QUESTIONS AND CLARIFICATION:

1. The chain link fencing surrounding the pool has bushes/trees that have grown around the fencing. Contractor shall remove as much fencing as possible and leave the bushes/trees in place.
2. All green 55 gallon plastic barrels in the pump room shall be removed prior to the start of the demolition. Contractor is not responsible for disposal of barrels or any product within barrels.
3. The small kid's pool shall be removed in its entirety.
4. The concrete sidewalk and steps leading up to the pool from the street shall be removed as will the pool sign and all 4" x 4" posts.
5. The contractor shall pump out the pool water to Dresden Drive where it will drain to the Stormwater drain inlet located at east edge of property.
6. It is the Contractor's responsibility to determine how many holes shall be punched in the bottom of the pool to facilitate drainage.
7. Pool will be open from 10:00 am to 11:00 for further inspection by contractors.
8. Right-of-Way permits are required.