



INVITATION FOR BIDS

2010-6154-1505

May 18, 2010

City of Newport News

OFFICE OF THE PURCHASING DIRECTOR

2400 Washington Avenue

Newport News, VA 23607

Phone: (757) 926-8041/ Fax: (757) 926-8038

www.nngov.com/purchasing

Harwood's Mill WTP Backwash Air Scour Blower Replacement Project, Contract No. 84

ADDENDUM 1

It is agreed and understood that the following changes shall be made part of the original Invitation for Bids (IFB)

This published addendum consists of one (1) page as follows:

- 1. Addendum Cover page - Addendum announcement and description of change.*
- 2. Revise Section 15100, 2.05, A,1 to read as follows:*

Victaulic type couplings and fittings may be used in lieu of flanged joints unless specifically shown otherwise on the Drawings. Pipes shall be roll grooved as specified by the manufacturer for use with the Victaulic couplings. Flexible Victaulic couplings shall be style 77S for 12-inch diameter pipe (or less) where shown on the drawings. Flanged adapter connections at fittings, valves, and equipment shall be Victaulic Vic Flange Style 441, or equal by Gustin-Bacon Group, Division of Certain-Teed Products, Kansas City, Kansas.

Bid Due: May 25, 2010 @ 2:30 p.m.

Contract Officer:

Marie-Therese (Mimi) M. Gartner, CPPB, Sr. Buyer, (757) 926-8040, email: mgartner@nngov.com

PLEASE INCLUDE THIS SIGNED ADDENDUM PAGE WITH YOUR SUBMITTAL

Company Name: _____

Print Name: _____ Title: _____

Signature: _____ Date: _____

(This Form Must Be Signed. Signature must be original, not photocopied)