



## ADDENDUM #3

IFB # 2011-1794-0205, Martin Luther King Plaza

September 3, 2010

City of Newport News  
OFFICE OF THE PURCHASING DIRECTOR  
2400 Washington Avenue  
Newport News, VA 23607  
Phone: (757) 926-8042/ Fax: (757) 926-8038  
[www.nngov.com/purchasing](http://www.nngov.com/purchasing)

Sealed proposals, subject to the conditions and instructions contained herein, will be received at the above office of the Purchasing Director, 4th Floor, City Hall, 2400 Washington Avenue, Newport News, Virginia, 23607, until the time and date shown below (local prevailing time), for furnishing the items or services described in the request for proposal.

**It is agreed and understood the following changes will constitute Addendum #3, and shall be made part of the original IFB document.**

**Note the following change:**

1. See attached page for additional requirements/clarifications.
2. Written questions submitted to the attention of the Contract Officer named below will be accepted through 5:00 PM, September 8, 2010.

**The bid submittal deadline remains scheduled at 2:00 PM, September 10, 2010.**

Contract Officer:   
Greg Smith, CPPB, C.P.M, Business Analyst C, [gsmith@nngov.com](mailto:gsmith@nngov.com)

Company Name: \_\_\_\_\_

Address: \_\_\_\_\_

City/State/Zip: \_\_\_\_\_

Telephone: \_\_\_\_\_ FAX No.: \_\_\_\_\_

E-mail: \_\_\_\_\_

Print Name: \_\_\_\_\_ Title: \_\_\_\_\_

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

*This Form Must Be Signed.*

The question below was submitted by a vendor:

Please provide information concerning the requirements of the alternate bid item for the solar array system, as there are no specifications for this item included in the bid package for this project.

ALSO – what is the Solar Array going to power? 3600w of power is only part of the info required to do this correctly...is the entire 3600w going to be powered Dust to Dawn, 3 hours, 6 hours, ????, etc...this determines actual battery size required....or do they just want a quote on a panel.....

Below is the City's response, which shall be incorporated into the contract requirements:

See specification section 13650 in Addendum #2.

The lighting will operate from the solar source except during evening special events.

During these special events, commercial power will supply the lighting and receptacles.

Estimated loads are: 2100W dusk to dawn operation, 400W for 6hr operation.

Additional Items:

- Specification Section 02870 - 2.3 Unit Pavers
  - Paver Type A to be 2 3/4" thick in lieu of 2 3/8".
- Specification Section 02870 - 2.4 Setting Bed
  - Crushed stone will not be allowed, washed natural sand will be used

End of Addendum #3