



ADDENDUM # 1

Roadway Improvement Project: Old Oyster Point Road and Canon Blvd.

IFB #2011-1818-0205

September 13, 2010

City of Newport News

OFFICE OF THE PURCHASING DIRECTOR

2400 Washington Avenue

Newport News, VA 23607

Phone: (757) 926-8032/ Fax: (757) 926-8038

www.nngov.com/purchasing

Sealed bids, subject to the conditions and instructions contained herein, will be received at the above office of the Purchasing Director, 4th Floor, City Hall, 2400 Washington Avenue, Newport News, Virginia, 23607, until the time and date shown below (local prevailing time), for furnishing the items or services described in the Invitation For Bid.

It is agreed and understood this and any following pages will constitute addendum # 1, and shall be made part of the IFB document. Acknowledgement, showing receipt and acceptance of the changes is to be returned in the manner specified above.

The Bid Submittal Date/Time is: September 21, 2010 at 3:00 P.M.

Contract Officer: _____

Greg Smith, CPPB, C.P.M, Business Analyst C, gsmith@nngov.com

Company Name: _____

Print Name: _____

Title: _____

Signature: _____

Date: _____

The following response to a vendor submitted question shall be applicable to the contract.

Question: I do not see any specs for item 81 UPS and SUPPLEMENTAL Cabinet. Please advise as to the intent of what needs to be provided?

City Response: The UPS shall be a 4 battery system with an Automatic Transfer Switch in a Supplemental cabinet to be attached to the control cabinet. The battery backup system shall be good for a minimum of four hours.

End of Addendum #1