



Addendum 2

IFB #2011-2361-2005

October 8, 2010

City of Newport News Office of the Purchasing Director

2400 Washington Avenue

Newport News, VA 23607

Phone: (757) 926-8032 Fax: (757) 926-8493

www.nngov.com/purchasing

FOAM COATED RE-ROOF PROJECTS

Sealed bids, subject to the conditions and instructions contained herein, will be received at the above office of the Purchasing Director, 4th Floor, City Hall, 2400 Washington Avenue, Newport News, Virginia, 23607, until the time and date shown below (local prevailing time), for furnishing the items or services described in the Invitation For Bid.

It is agreed and understood this and the following pages will constitute addendum # 1, and shall be made part of the IFB document. Acknowledgement, showing receipt and acceptance of the changes is to be returned in the manner specified above.

Change to Sheet A-1 Seafood Industrial Building:

1. Add the following note to sheet A-1 Seafood Industrial Building, " The existing metal roof sheets shall be trimmed back flush to the existing eaves. Install additional fasteners to the roof sheet eave edge, 2 per each panel."

Questions, answers and clarification on the following pages shall be applicable to the contract.

Bid Due Date: 2:00 p.m., October 12, 2010

Shari D. Colvin

Contract Officer: _____

Shari D. Colvin, CPPB, VCO, Deputy Director, scolvin@nngov.com

Company Name: _____

Print Name: _____ Title: _____

Signature: _____ Date: _____

This Form Must Be Signed

Questions, Answers and Clarification for Foam Coated Re-Roofing Projects:

1. The EPDM membrane to be removed at Pearl Bailey Library. This material can be recycled in lieu of depositing in a landfill Is this a requirement?
The existing EPDM roof material shall be recycled.
2. The special conditions require a project sign. Is signage required at each location or will one sign that is used at all locations acceptable?
One project sign is required and shall be relocated to each roof location.
3. In the Specification 075700-8, 3.5, A., 1., “Minimum thickness on horizontal surfaces shall be 1”...” the drawings indicated a minimum of 1 ½” installation and this thickness is the minimum requirement by the manufacturer of the system. Please clarify.
The minimum thickness for each roof location shall be as indicated on the drawings for that particular roof. The minimum thickness indicated however shall not be less than the manufacturer’s minimum requirement.