




ADDENDUM #3
Demolition of 373 Poplar Avenue for Department of
Engineering Stormwater Management Pkg. #3-2010 ___
IFB #2011-2699-1705
November 05, 2010
City of Newport News
Office of the Purchasing Director
2400 Washington Avenue
Newport News, VA 23607
Phone: (757) 926-8032/ Fax: (757) 926-8038
www.nngov.purchasing

Sealed bids, subject to the conditions and instructions contained herein, will be received at the above office of the Purchasing Director, 4th Floor, City Hall, 2400 Washington Avenue, Newport News, Virginia, 23607, until the time and date shown below (local prevailing time), for furnishing the items or services described in the invitation for bids.

It is agreed and understood this will constitute addendum #3, and shall be made part of the original IFB document. Acknowledgement, showing receipt and acceptance of these two changes is to be returned with your submittal.

Bid Due: November 09, 2010 @ 2:30 P.M.

Addendum #3 includes: Questions and Answers and Paragraph Change: Section C, Special Construction Conditions, page SCC – 3, #16.

Contract Officer: 
Kimberly A. Kapalka, C.P.M., Senior Buyer, kkapalka@nngov.com

Company Name: _____

Print Name: _____ Title: _____

Signature: _____ Date: _____

This Form Must Be Signed. Signature must be original, not photocopied, Page 1 of 1

Questions and Answers

1. **Is there any other additional information or clarification on the permits and bonds that are required for the Demolition of 373 Poplar Avenue for Department of Stormwater Engineering Management Pkg. #3-2010. I am not sure what needs to be provided for the Public Right of Way permit/bond and the Soil Removal and Land disturbance bond. Any help with this would be greatly appreciated.**

The \$5,000 bond is required. FURTHER INFORMATION PERTAINING TO THE RIGHT OF WAY PERMIT can be obtained by calling Engineering at 926-8611 and ask for Permits.

Section C, Special Construction Conditions, Item #9, states the area to be disturbed will be less than 2,500 square feet and therefore the \$2,000.00 Soil Erosion bond is not required.

Paragraph Change Section C, Special Construction Conditions, page SCC – 3, #16.

Change From: Contractor shall be responsible for all submittals per 40 CFR part 61, subpart M- National Emission Standard for Hazardous Air Pollutants (NESHAP) and these specifications. When submittals are required Contractor shall send written notice by facsimile or certified mail, return receipt, for demolition work being performed to the following and submit copies of these notices to the Engineer prior to any work being performed.

Asbestos Control Clerk
Department of Labor and Industry
Powers-Taylor Building
13 South Thirteenth Street
Richmond, VA 23219

Asbestos NESHAP Coordinator
3WC32
U.S. EPA, Region III
1650 Arch Street
Philadelphia, Pa 19103

Change To: Contractor shall be responsible for all submittals per 40 CFR part 61, subpart M- National Emission Standard for Hazardous Air Pollutants (NESHAP) and these specifications. When submittals are required Contractor shall send written notice by facsimile or certified mail, return receipt, for demolition work being performed to the following within ten (10) days of notice of intent to award and submit copies of these notices to the Engineer.

**Asbestos Control Clerk
Department of Labor and Industry
Powers-Taylor Building
13 South Thirteenth Street
Richmond, VA 23219**

**Asbestos NESHAP Coordinator
3WC32
U.S. EPA, Region III
1650 Arch Street
Philadelphia, Pa 19103**