



Addendum 2

IFB #2011-3362-2005

December 20, 2010

City of Newport News Office of the Purchasing Director

2400 Washington Avenue

Newport News, VA 23607

Phone: (757) 926-8032 Fax: (757) 926-8493

www.nngov.com/purchasing

LED STREETLIGHTS INSTALLATION ON JEFFERSON AVENUE AND HARPERSVILLE ROAD

Sealed bids, subject to the conditions and instructions contained herein, will be received at the above office of the Purchasing Director, 4th Floor, City Hall, 2400 Washington Avenue, Newport News, Virginia, 23607, until the time and date shown below (local prevailing time), for furnishing the items or services described in the Invitation For Bid.

It is agreed and understood this and the following page will constitute addendum 2, and shall be made part of the IFB document. Acknowledgement, showing receipt and acceptance of the changes is to be returned in the manner specified above.

This published addendum consists of questions, answers and clarification.

Bid Due Date: 2:00 p.m., December 28, 2010

Shari D. Colvin

Contract Officer: _____

Shari D. Colvin, CPPB, VCO, Deputy Director, scolvin@nngov.com

Company Name: _____

Print Name: _____ Title: _____

Signature: _____ Date: _____

This Form Must Be Signed

Questions, Answers, Clarification - LED Streetlights Installation on Jefferson Avenue and Harpersville Road

1. Page PS-1 and PS-2. How many construction project signs will be required?

One sign will be required for this project.

2. Page B-6 requires Schedule 40 conduit and Page B-2 requires Schedule 80 conduit. Which is correct?

Item 12- 1 ½" Schedule 80 HDPE conduit under paved surfaces

Item 13- 1 ½" Schedule 40 PVC conduit in green areas

Item 14- 4" Schedule 40 PVC conduit at cabinet station

3. Page B-2, Item 21 and 22 indicates **supply only of 221W and 113W Beta LEDway**. Page B-10 - **Beta LEDway Streetlights Supply Only** indicates the unit price to include streetlight poles, arms, Beta LEDway fixtures, excavation, installation, fill and seed. Which is correct? Are we to supply both fixtures and poles?

For Items 21 and 22, this will be to supply fixtures only. This shall include delivery to:

513 Oyster Point Road

Newport News, Virginia

Attn: Traffic Signal Superintendent.

(Answer to Question 3 also applies to Page C-3, ITEM NO. 21 and ITEM NO. 22.)