



ADDENDUM 1
City of Newport News
IFB#2011-3384-2005

December 3, 2010

Purchasing Department, Office of the Purchasing Director
4th Floor, City Hall, 2400 Washington Avenue
Newport News, VA 23607

Phone: (757) 926-8031/ Fax: (757) 926-8038

<http://www.nngov.com/purchasing>

NEWPORT NEWS LIGHTING UPGRADE

Sealed bids subject to the conditions and instructions contained herein, will be received at the above office of the Purchasing Director, 4th Floor, City Hall, 2400 Washington Avenue, Newport News, Virginia 23607, until the time and date shown below (local prevailing time), for furnishing the items or services described in the bid.

It is agreed and understood this page and the following page will constitute addendum 1, and shall be made part of the IFB document. Acknowledgement, showing receipt and acceptance of the changes is to be returned in the manner specified.

Bid Due: 3:00 p.m., December 21, 2010

Shari D. Colvin

Contract Officer: _____
Shari D. Colvin, CPPB, Deputy Director, scolvin@nngov.com

Company Name: _____

Address: _____

City/State/Zip: _____

Telephone: _____ FAX No.: _____

E-mail: _____

Print Name: _____ Title: _____

Signature: _____ Date: _____

This form must be signed. All signatures must be original and not photocopies.

1. I am interested in bidding an "or equal" to the BETA LED luminaire specified but cannot determine from the bid document the number of LED's the luminaire will use. This information is typically part catalog number but I did not see it.
Further, I see no requirement regarding lumen output specified.

Under "LIGHTING CHARACTERISTICS", the minimum lumen output requirement is specified. Without forgoing the other specified requirements including lumen output and aesthetics, a fixture can contain any number of LEDs and wattage (within the specified range) etc.

2. I would also be interested in the pole height data.

Pole height varies depending upon the streetlight location. Generally, 25' for Bid Item # 1, 11' for Bid Item # 2, and 12' for Bid Item # 3 can be used.

3. The following is a list of locations per bid item number.

Bid Item #1: Mercury Blvd. – Between James River Bridge and Warwick Blvd., 39th St. Bridge, Bland Blvd. Bridge, and Denbigh Blvd. Bridge

Bid Item #2: Downtown, Hilton Village

Bid Item #3: Port Warwick

Questions regarding this IFB should be directed to the Department of Purchasing, Shari D. Colvin, by email: scolvin@nngov.com and copy Brenda Vines@nngov.com by 1:00 p.m., December 15th. All questions must be submitted in writing, other inquiries will not be considered.